

Certificate No. 164349

TEST TO DETERMINE THE COEFFICIENT OF THERMAL TRANSMITTANCE

Test Standards:


UNE-EN 12412-4:2005. Thermal efficiency of windows, doors and shutters. Determination of thermal transmittance by means of the hot box method. Part 4: Roller shutter box

Company **GIMENEZ GANGA, S.L.U. SHUTTERS**
**THE CASTLE INDUSTRIAL
PARK C/ ROMA N°4, SAX
(ALICANTE).**

Section

Product	SHUTTER BOX
Model	EURODECOR 155
Dimensions (AnxAI)	1230 mm x 155,3 mn
Material	PVC

Trial Date **05/02/2008**



**Normalised Thermal Transmittance
(U_{sb})**

1.9 W/(m²K)



ENSATEC S.L. - February 2008

Oscar Ruiz Chicote
Rpble. Ext. Enclosures Area

Luis García Viguera
Construction Department

José Morales Henares
Director Managing Director

This certification is concomitant with test report reference No. 164349.