

RESISTANCE TO WIND LOAD TEST

Company

GIMÉNEZ GANGA, S.L.U. SHUTTERS SAX.
ALICANTE

Test standards.
Resistance to wind load. Section 7.4
Safetycheck to positive pressures.

Section and/or photograph:

Product

COMPACT EURODECOR ABS 155

Model

EURODECOR 155

Dimensions
(AnxAI)

1230 mm x 155 mm

Material

EURODECOR 155


Box

PVC

End caps

PVC

Trial Date 10.01.08



CE

Classification Standards:
Resistance to wind load UNE-EN 12210
AC:2002- Windows and
doors. Resistance to wind load

Resistance to wind load
Safety check

3000 Pa

Oscar Ruiz Chicote

Luis García Viguera

José Morales Henares

This certification is concomitant with test report reference No. 173755.