

Certificate No. 164297

AIR PERMEABILITY AND WATERTIGHTNESS TESTS

Trial Date 14/01/2008


Test Standards:
UNE-EN 1026:2000. Windows
and doors. Air permeability
UNE-EN 1027:2000. Windows
and doors. Watertightness.

Company GIMÉNEZ GANGA, S.L.U. SHUTTERS
AUTOVIA DE LEVANTE, KM 42 SAX. VALENCIA

Section

Product	COMPACT EURODECOR 185
Model	EURODECOR 185
Dimensions (AnxAI)	1230 mm x 185 mm
Box Material	PVC

End Caps Material PVC



QñJtM PCD DJDBUDt-raS
PVC

Air permeability

CLASS 3

Watertightness

E3000

NOTIFIED BODY No. 1668
for the assessment of conformity with the
product directive of construction
89/106/CE

This certification is concomitant with test report reference No. 164297.



Classification Standards:
UNE-EN 12207:2000. Windows
and doors. Air permeability UNE-
EN 12208:2000. Windows and
doors. Watertightness.

ENSATEC/SX. . - February 2008

Oscar Ruiz Chicote Rpble. Ext.
Enclosures Area

Luis García Viguera
Construction Department
Director

José Morales Henares
Managing Director